

NTPC Health & Safety Alert

Incident Summary – July 2016



Background

The following incidents took place in July, 2016. Medium and High Reasonable Potential for Harm (RPH) incidents are covered in more detail in separate Alerts.

Incident Summary

07-12-16, Inuvik, public incident, High RPH:

- Event: Track drill snagged and damaged a service wire.
- Response: Damages repaired, WSCC informed of contact, company educated on avoiding electrical contact and what to do if it happens.

07-14-16, Behchoko, public incident, High RPH:

- Event: Dump truck brought down a line and tore mast from house.
- Response: Area made safe, WSCC informed of contact, company educated on avoiding electrical contact and what to do if it happens.

07-19-16, Fort McPherson, NTPC incident, Low RPH:

- Event: 120 L of glycol spilled in plant due to broken frost plug.
- Response: Cleaned up, reported. Plug inspection frequency increased.

07-22-16, Fort Liard, NTPC incident, Low RPH:

- Event: Minor consuming alcohol in transient trailer.
- Response: RCMP called, NTPC staff secured site.

