



The Northwest Territories Power Corporation



2010/11 Greenhouse Gas Report



TABLE OF CONTENTS

Message from our President	1
Introduction	2
Corporate Profile	2
Commitment to Reducing Greenhouse Gas Emissions	3
Management System	3
External Verification	3
Base Year Quantification	4
Baseline Quantification	4
Direct and Indirect Emissions	4
Emissions Calculations	5
Forecast Emissions	5
2010/11 Greenhouse Gas Emissions	6
Hydropower Generation	6
Diesel Generated Power	6
Natural Gas Generated Power	7
Actual Emissions for 2010/11	7
Emissions Intensity	8
Forecast Emissions	8
Natural Gas Generation Developments	9
Business as Usual Forecasting	9
Emissions Reductions Targets	10
Results Achieved and Measures to Achieve Results	11
Fuel Efficient Engine Upgrades	11
Programmable Logic Controllers (PLC)	12
Reduction in Station Service / Residual Heat Recovery	12
Colville Lake Residual Heat Project	13
Fort Smith Electric Heat Project	14
Jackfish Electric Boiler Installation	14
Alternative Generation Fuels / Methods	14
Bluefish Hydro Purchase	14
Proposed Hydro Developments	14
Mini Hydro in Lutsel K'e	15
Streetlight Replacement	15
Transmission and Distribution Lines	15
Residential Energy Efficiency Program	16
Results in Comparison to Targets	16
GHG Emissions	16
CO ₂ e Station Service Target	16
Climate Change Awareness	17
Internal Communications	18
Conclusion and Contact Information	19
APPENDIX A	20


Message from our President and Chief Executive Officer

On behalf of the Northwest Territories Power Corporation I am pleased to submit this year's Greenhouse Gas (GHG) Report to the Canadian GHG Challenge Registry. This year marks our Company's 12th annual submission. Since our first GHG report submission in 1999 we have annually achieved Gold Champion Level Reporting Status.

This report reflects our ongoing commitment to manage GHG emissions and provides a detailed update of our Company's GHG emission inventory and emission reduction initiatives. In 2010/11 NTPC produced 68,605 Tonnes of CO₂ equivalent (CO₂e) GHG emissions, a successful decrease of 51% from 1990/91 levels (Baseline). This decrease was made possible by increasing hydroelectric and natural gas generation, reducing diesel generation, and various other GHG reduction initiatives.

Through programs to increase Corporation-wide fuel efficiency, reduce our own station service demands, promote public awareness of energy efficiency, and carry out research into alternative sources of power generation, we will continue to strive to reduce GHG emissions where feasible. We will also continue to monitor and publicly report on our initiatives, progress, and success in reducing greenhouse gas emissions in the north.

Sincerely,



Emanuel DaRosa
President and Chief Executive Officer



INTRODUCTION

The Canadian GHG Challenge Registry (Registry) provides a nationally recognized and reviewed avenue for businesses to report Greenhouse Gas (GHG) emissions. Through the Registry, the Northwest Territories Power Corporation (NTPC, Corporation) demonstrates its ongoing commitment to voluntarily reduce GHG emissions. Since our first annual submission to the Voluntary Challenge and Registry (predecessor to the Registry) in 1999, we have achieved Gold Champion Level Reporting Status yearly. We also received the *Best New Submission* award in 1999 and the *Leadership Award for the Electric Utilities Sector* in 2001, as well as honourable mentions in 1999 and 2003 for the Leadership Award. NTPC is proud to present our 2010/11 GHG report. In this report, we quantify our air emissions and outline the many initiatives taken to further reduce GHG emissions and help preserve one of the world's most beautiful and pristine environments.

on a wholesale basis to two distributing utilities. These utilities in turn retail electricity to customers in the Yellowknife and Hay River areas.

NTPC's facilities include hydroelectric, diesel, and natural gas generation plants, as well as transmission systems and numerous isolated electrical distribution systems. NTPC operates 31 power plants including the standby diesel generation facilities within the Bluefish, Snare, and Taltson hydro systems and the Inuvik and Norman Wells natural gas systems. NTPC purchases and distributes natural gas generated power in Norman Wells. We also own and operate alternative energy assets used for the supply of residual heat, solar power, and cogeneration in several communities. Figure 1 shows the NWT and the locations of communities served by NTPC.

Figure 1: NTPC Service Area



Corporate Profile

The Northwest Territories Power Corporation is a Crown corporation wholly owned by the Government of the Northwest Territories. NTPC was created in 1988 when the Territorial Government purchased shares of the federally owned Northern Canada Power Commission. Today we are the primary power producer in the Northwest Territories (NWT). We distribute electricity to the end-use consumer in 25 communities and supply electricity



NTPC serves a population of approximately 42,700 people located in an area of 1.3 million square kilometers. Approximately 69% of the population lives in the North and South Slave regions, while the rest of the population resides in small communities widely dispersed throughout the NWT. The total electrical load for the NWT is approximately 73 MW, with isolated power systems having generating capacities ranging from 230 kW at Jean Marie River to 62 MW at Snare/Yellowknife (including Bluefish Hydro). As these systems are isolated and unconnected, each must be planned for and operated independently.

NTPC exists in a unique operating environment that has a profound impact on NTPC's operations throughout its service area. Extremely low customer densities, a harsh climate, a mix of hydro/diesel/natural gas generation, and the lack of an integrated transmission system present logistical challenges that set NTPC apart from most utilities.

Commitment to Reducing GHG Emissions

NTPC's long term vision includes a commitment to the environment. Each year Senior Management and the Board of Directors approve strategies to achieve specific goals with respect to environmental performance, including GHG reduction. In addition, NTPC has environmental and capital plans that are approved annually by the Board and reviewed quarterly. These plans include actions to reduce GHG such as alternative energy projects, streetlight conversions, and engine replacements.

Twice annually NTPC files a report with the regulator outlining actions taken to implement alternative energy, demand side management, and energy efficiency initiatives.

Although we have already achieved our target to reduce GHG emissions by 10% of 1996/97 levels, we will continue to further decrease our production of GHG emissions where feasible.

NTPC has developed an ISO 14001 compliant Environmental Management System (EMS). The EMS includes a review of current climate change

practices implemented by NTPC, which will help develop and monitor new targets.

Management System

Our GHG emissions are monitored at the most senior levels of NTPC by the Board of Directors and the President and CEO. Senior Management not only review and approve NTPC's Strategic Plan, but review and approve any GHG initiatives through the annual capital and financial planning process. The Minister responsible for NTPC is also advised of all major issues regarding NTPC including our GHG reduction programs.

Through our annual GHG submission we analyze and monitor NTPC's success in reducing GHG emissions. Corporate data from the Environmental, Financial, and Engineering departments is compiled, analyzed and reviewed at a management level to generate the GHG report. The President and CEO reviews the report prior to submission to the Registry. Once submitted, NTPC's GHG emissions status is reported to both the Board of Directors and the Minister.

External Verification

The Auditor General of Canada annually carries out external verification of Corporation data, including fuel consumption and generation statistics.

In accordance with the Public Utilities Board (PUB) process for setting power rates all aspects of our operations, including our GHG initiatives and their associated costs and benefits, are reviewed publicly and by the PUB.

In 2003 Environment Canada's National Pollutant Release Inventory (NPRI) introduced Criteria Air Contaminants (CACs) into their list of toxic substances to be reported annually. In 2008 the Canadian Electricity Association (CEA) created the Sustainable Electricity Report which requires reporting of environmental, social and economic indicators. NTPC now reports emissions annually to the NPRI, CEA, and to the Registry.

BASE YEAR QUANTIFICATION

NTPC used the 1990/91 fiscal year to create a Baseline for emissions against which to compare subsequent years.

Baseline Quantification

Emission factors from Environment Canada's GHG Inventory were used to calculate emissions. Table 1 illustrates our 1990/91 Baseline emissions according to GHG type.


Table 1: Baseline Emissions Estimates by Greenhouse Gas Type

Fiscal Year	Tonnes			Total Emissions
	CO ₂	CH ₄	N ₂ O	
1990/91	132,610	10	19	138,787



Hydro, diesel, and purchased natural gas generated power accounted for 61%, 37%, and 2% of total generation in 1990/91, respectively. Figure 2 illustrates 1990/91 percent generation according to source.

Figure 2: Power Generation by Source for 1990/91



Direct and Indirect Emissions

NTPC's direct GHG emissions result from the combustion of fossil fuels to generate electricity in Corporation-owned diesel and natural gas facilities.

Indirect emissions are those created or saved by operations not directly controlled by NTPC, but affected by Corporation business decisions. These include emissions produced from purchased natural gas generated power and emissions saved as the result of residual heat projects providing heat to buildings not owned by NTPC.

In 1990/91 NTPC did not own any natural gas generating facilities. All natural gas generation emissions at that time were therefore indirect emissions resulting from the purchase of natural gas generated power in Norman Wells. Table 2 illustrates NTPC's emissions according to source for 1990/91.

Table 2: Baseline GHG Emissions by Source

Fiscal Year	CO ₂ Equivalent Tonnes		Total Emissions
	Diesel Generation	Gas Generation	
1990/91	133,395	5,392	138,787

Emissions Calculations

Greenhouse gas emissions are calculated using actual fuel consumption data and emission factors. In previous reports the emission factors came from the GHG Registry Guide. For the last two years emission factors were provided by Environment Canada's GHG Inventory, which are significantly different than the GHG Registry emission factors (see Table 3). The new emission factors were applied to all previous year's data to provide a valid comparison.

Source	CO ₂	CH ₄	N ₂ O
Natural Gas Env. Canada	2,454 g/m ³	0.49 g/m ³	0.049 g/m ³
Natural Gas GHG Registry	1,891 g/m ³	0.49 g/m ³	0.049 g/m ³
Diesel Env. Canada	2,663 g/L	0.133 g/L	0.40 g/L
Diesel GHG Registry	2,730 g/L	0.13 g/L	0.40 g/L

The following equivalency factors provided in the Registry Guide were utilized to calculate GHG carbon dioxide equivalency (CO₂ e):

Table 4: Carbon Dioxide Equivalency Factors

Greenhouse Gas Type	CO ₂ e Factor
CO ₂	1
CH ₄	21
N ₂ O	310

Corporation buildings heated by residual heat or electricity directly from Corporation power plants are included in emissions estimates, however emissions produced from oil-fired furnaces in Corporation owned housing, Corporation office buildings, etc. are not reported.



Due to the low number of Corporation owned vehicles (61 on average) and the limited distances driven annually, GHG emissions produced from vehicles are not included in this report.



Forecast Emissions

Forecast emissions are based on predicted future power generation values for 2011/12 to 2014/15, which are divided by three-year weighted averages for plant efficiencies to determine fuel consumption. This method of forecasting incorporates the previous year's improvements to fuel efficiencies, upgrades to streetlights and transmission lines, and reductions to station service.

Average hydro generation (assuming normal precipitation levels, as most water comes from runoff) is used to forecast the amount of diesel generation required for those communities where diesel generation supplements hydro generation.



2010/11 GHG EMISSIONS


Diesel combustion for the production of power is our major source of GHG emissions. Since 1990 diesel generated emissions have accounted for an average of 81% of our total GHG emissions. The following section illustrates Corporation production of GHG emissions and the efforts taken in the last year to reduce our reliance on diesel generated power.

Hydropower Generation

Hydropower generation is dependent on water levels and thus varies from year to year. In years of low hydropower generation, diesel generation is increased to meet hydro shortfalls. The majority of NTPC's GHG emissions result from diesel generation, so when hydro generation is low, GHG emissions increase. 2010/11 was an average water level year, resulting in an average amount of hydro generation.

Hydropower is currently the cleanest power NTPC can provide to its customers. As diesel generation is utilized as backup power generation for the hydro systems, the more hydropower we are able to produce the more diesel generated power we displace. Figure 3 shows NTPC's average power generation by source for 1990/91 and 2010/11.

Figure 3: Average Power Generation by Source for 1990/91 and 2010/11



In 2010/11 the Bluefish, Snare, and Taltson hydro systems produced 33,832 MWh, 155,831 MWh, and 67,509 MWh of power respectively, totalling 74% of total generation (13% more than 1990/91). In the absence of hydropower, all this power would have been generated from diesel.

Diesel Generated Power

NTPC's consumption of diesel fuel for generation purposes, our major source of GHG emissions, has greatly decreased over the years. In 1990/91, 37% of total generation came from diesel generated power. In 2010/11, diesel generated power accounted for only 17% of total power generation. Our decreased reliance on diesel generated power has allowed us to reduce our diesel generated CO₂ equivalent emissions from 133,395 tonnes in 1990/91 by 65% to 46,394 tonnes in 2010/11. Table 5 shows NTPC's CO₂ equivalent emissions from both direct and indirect generation sources.

Table 5: GHG Emissions Produced/Gen. Source

Fiscal Year	Direct		Indirect	Total Emissions
	Diesel Generation	Natural Gas Generation	Natural Gas Generation	
CO ₂ e Emissions (Tonnes)				
1990/91	133,395	0	5,392	138,787
1991/92	127,090	0	5,455	132,545
1992/93	129,164	0	5,492	134,656
1993/94	132,788	0	5,787	138,575
1994/95	173,572	0	5,753	179,325
1995/96	173,985	0	5,125	179,110
1996/97	120,774	0	4,858	125,632
1997/98	102,387	0	5,420	107,807
1998/99	91,336	0	5,451	96,787
1999/00	53,023	8,552	5,103	66,678
2000/01	48,146	14,610	5,034	67,791
2001/02	46,633	16,663	5,030	68,326
2002/03	61,827	16,451	5,135	83,413
2003/04	69,033	17,034	5,915	91,982
2004/05	59,937	17,174	5,650	82,761
2005/06	41,461	16,661	5,449	63,571
2006/07	37,996	20,296	5,926	64,219
2007/08	50,246	20,882	5,997	77,126
2008/09	42,530	20,775	5,810	69,114
2009/10	39,305	20,907	5,711	65,922
2010/11	46,394	16,655	5,556	68,605

Natural Gas Generated Power

NTPC continues to replace diesel generated power with less GHG intensive natural gas generated power. In 1990/91 NTPC's only source of natural gas generated power was purchased power in Norman Wells, which accounted for 2% of NTPC's total generation. In 2010/11 NTPC produced 9% of its total generation from natural gas generated power; 7% NTPC-generated power and 2% purchased power. This means NTPC successfully produced approximately 7% more natural gas generated power in 2010/11 than in 1990/91. The replacement of remaining Inuvik diesel engines with natural gas engines in 2006/07 has resulted in a greater percentage of natural gas generated power and a decrease in emissions intensity.

Actual Emissions for 2010/11


Once again NTPC was able to produce fewer emissions per MWh than in 1990/91. This was accomplished by maximizing hydro and natural gas generated power over the more GHG intensive diesel generation. In 2010/11 NTPC produced 68,605 tonnes of CO₂ equivalent emissions, a decrease of 51% from 1990/91 levels. NTPC's GHG emissions remain well below both the 1990/91 Baseline levels and NTPC's internal target of 10% below 1996/97

levels. Figure 4 illustrates NTPC's GHG emissions from 1990/91 to 2010/11 while Table 6 illustrates our GHG emissions according to gas type and emissions intensity from 1990/91 to 2010/11.

Table 6: GHG Emissions by Gas Type

Fiscal Year	Tonnes			Total CO ₂ Equivalent Emissions	Emission Intensity (Tonnes/MWh)
	CO ₂	CH ₄	N ₂ O		
1990/91	132,610	10.37	19.22	138,787	0.372
1991/92	126,655	10.01	18.32	132,545	0.351
1992/93	128,672	10.12	18.62	134,656	0.335
1993/94	132,426	10.22	19.15	138,575	0.334
1994/95	171,323	12.11	24.99	179,325	0.440
1995/96	171,100	11.82	25.04	179,110	0.420
1996/97	120,042	9.25	17.40	125,632	0.298
1997/98	103,053	8.17	14.78	107,807	0.262
1998/99	92,547	7.09	13.20	96,787	0.262
1999/00	64,121	5.56	7.87	66,678	0.173
2000/01	65,402	6.18	7.29	67,791	0.176
2001/02	67,225	6.51	7.11	68,326	0.173
2002/03	80,382	7.21	9.29	83,413	0.209
2003/04	88,609	7.83	10.35	91,982	0.234
2004/05	79,802	7.37	9.04	82,761	0.222
2005/06	61,459	6.35	6.38	63,571	0.186
2006/07	62,223	6.99	5.97	64,219	0.186
2007/08	74,566	7.71	7.74	77,126	0.217
2008/09	66,908	7.28	6.62	69,114	0.204
2009/10	63,863	7.13	6.16	65,922	0.196
2010/11	66,268	6.60	7.09	68,605	0.198

Figure 4: Total CO₂ Equivalent Emissions between 1990/91 and 2010/11



Emissions Intensity

Emissions intensity is a product of the CO₂ equivalent emissions produced in relation to total power generation from all sources (tonnes/MWh). As diesel generated power is our major source of GHG emissions, the lower our emissions intensity the more successful we are at meeting our power generation demands from other, cleaner sources.

NTPC generated 6,284 MWh more hydro generated power in 2010/11 than in 2009/10. This translates into a GHG emissions intensity of 0.198 tonnes/MWh for 2010/11, well below the 0.372 tonnes/MWh from 1990/91.

Forecast Emissions


NTPC's forecast GHG emissions for the period of 2011/12 to 2014/15 average 54% below the 1990/91 Baseline levels. Figure 5 illustrates forecast CO₂ equivalent emissions to 2014/15.

Forecast hydro generation is based on a long-term average water level forecast, and has a large influence on NTPC forecast emissions. With higher water levels anticipated total emissions are ex-

pected to be slightly lower than in 2010/11. This is due to the continued availability of Bluefish hydropower to displace diesel generated power in Yellowknife

The Bluefish Hydro facility, originally owned by Miramar, was built to supply power to Yellowknife's Con Mine, also owned by Miramar. In November of 2003 Con Mine terminated mining operations, significantly reducing its electrical requirements. NTPC purchased the Bluefish Hydro facility, and hydropower no longer required by the mine is now available to meet Yellowknife power demands, thereby reducing diesel fuel consumption. Between 2010/11 and 2014/15 we anticipate using an average of only 455 kL of diesel fuel annually to meet Yellowknife demands. This will produce only 1,300 tonnes of CO₂ equivalent emissions per year to service Yellowknife power demands, compared to the 54,612 tonnes produced in 1990/91. Figure 6 illustrates percent change in NTPC emissions relative to 1990/91 levels for actual and forecast years.

Figure 5: Forecast CO₂ Equivalent Emissions as a Product of Total Generation



Natural Gas Generation Developments

As a result of converting NTPC's main generating station in Inuvik from diesel to natural gas in 1999, NTPC made it feasible for the producers and distributors of natural gas to expand their local market. NTPC introduced another natural gas generator into the Inuvik plant in January 2006 giving the plant the capability of supplying 100% of the town's power demands with natural gas generated power. The diesel generators are now used only for backup generation.

NTPC has been working with the Town of Inuvik since 2002 with the installation and operation of two natural gas fired micro-turbine units to supply combined electricity and residual heat to the Town's recreation complex. This demonstration project is NTPC's first venture involving micro-turbines. Although the units have not performed as expected to date, they have contributed to GHG reductions in the community from the combined electricity and heat production of the micro-turbines.




When natural gas becomes more readily available to northern communities, NTPC will consider the economics and GHG reduction benefits of retrofitting existing diesel power plants to natural gas.

Business As Usual Forecasting

Past projects that have resulted in GHG reductions are reflected in our forecast emissions for the period between 2011/12 and 2014/15. The use of techniques such as three-year weighted averages for fuel efficiencies and using the most recent year's data to forecast future years helps to capture the trends that result in GHG reductions and to represent them in forecasts. This is how we develop our "Business As Usual" forecasts, which include existing efforts. This helps to improve our

Figure 6: GHG Emissions Percent Change Relative to Baseline Data



supply-side management through improved diesel engine efficiency programs, reduced station service, residual heat projects, upgraded streetlights, and reduced line losses from transmission and distribution systems.



Emissions Reductions Targets

As NTPC has successfully decreased its emissions below the 1990 Baseline and our own internal target of 10% below 1996/97 levels, we feel our "Business As Usual" forecast, capturing improved trends in our existing initiatives, is sufficient for the time being. Any major changes to our operating infrastructure will be adopted if they represent an economic benefit as well as a savings in GHG emissions.

RESULTS ACHIEVED & MEASURES TO ACHIEVE RESULTS

NTPC has successfully reduced GHG emissions through a number of programs since 1990/91. The following section describes individual initiatives taken in 2010/11 that contributed to GHG reductions and/or their impacts on future reductions.

NTPC endeavours to improve overall efficiency. Improving operating efficiency reduces reliance on fossil fuels to generate and distribute energy to customers. The benefits of improving efficiency reach beyond NTPC's direct emissions.

The vast geographic area and remoteness of the region means that significant resources and energy must be expended in order to transport fuel to each of NTPC's sites. By reducing the volume of fuel required to generate power the overall energy required to transport fuel to generating sites (derived from fossil fuels) is also reduced.

Examples of individual projects undertaken by NTPC to reduce dependence on fossil fuels and production of GHG emissions during 2010/11 follow below. Table 7 summarizes the cumulative aggregate savings for all initiatives from 1990/91 to 2010/11. The table in Appendix A shows actual and forecast GHG emissions savings by gas type as well as total CO₂ equivalent emissions for all initiatives since 1990/91 forecast to 2014/15. Please note that 1991/92, 1992/93, 1993/94 and 1994/95 data has been removed from the table to allow room for table expansion. Please see previous years' reports for this data.

Table 7: Cumulative Aggregate Emissions Savings (Tonnes) from All Initiatives since 1990/91

CO ₂ Equivalent Reductions (Tonnes) 1990/91—2010/11				
Alternative Generation/Fuels	Station Service Reduction/Residual Heat Projects	New Engine Upgrades/PLCs	Streetlight Upgrades	Total
881,587	9,816	73,441	3,873	968,717


Fuel Efficient Engine Upgrades

In recent years, diesel engine technology has aided in reducing the amount of emissions produced. Engine selection analysis is based primarily on life-cycle costs and the amount of emissions produced. The most significant of those life-cycle costs is fuel, which accounts for 85-90% of the capital and operating costs of a diesel engine over its life. Therefore, it is extremely important to replace aging equipment with units which are fuel-efficient, yet still produce the least amount of emissions possible. In 2010/11 NTPC installed two new diesel engines in two NWT communities.



Figure 7 illustrates our Corporate efficiency trend. Yellowknife and Inuvik, two of our largest diesel generating plants, operate as backup diesel generators in the event that hydro or natural gas generation become unavailable. Due to the low frequency with which these plants now operate, their fuel efficiencies have decreased accordingly. Therefore the Yellowknife and Inuvik plants have been excluded from this graph as they skew the data.

Figure 7: Corporate Fuel Efficiencies Excluding Yellowknife and Inuvik



The overall fuel efficiency for NTPC in 2010/11 (excluding standby plants) has improved by 11% over the 1990/91 efficiency.

Our day-to-day operations, maintenance, and capital planning focus on maintaining or improving our fuel efficiency. Therefore our upward trend in fuel efficiencies is reflected in our forecasts for fuel consumption, and hence our forecast GHG emissions.

Programmable Logic Controllers (PLC)

Programmable Logic Controllers automate power plant diesel engines and help ensure that the appropriate engine is operating to most efficiently service fluctuating loads. This contributes to improved plant fuel efficiency. As it is impossible to separate PLC efficiency improvements and gains from upgrading to more fuel-efficient engines, the benefits of PLCs and new engines are calculated together in the Fuel Efficient Engine Upgrades section.

The only plants without some level of PLC automation are Jean Marie River, a community of approximately 70 people, and Fort Smith, a backup plant to the Taltson hydro site.

Reduction in Station Service / Residual Heat Recovery

NTPC is continuously investigating ways to reduce its own consumption of power. Some of the equipment and design improvements utilized to reduce station service at our plants include:

- replacement of in-plant electric space heating with residual heat from engine jacket water systems;
- replacement of engine electric block heaters with residual heat circuits that utilize jacket water heat from operating engines;
- replacement of inefficient lighting;
- installation of separate lighting circuits so that only specific lights are on at certain times;
- installation of variable frequency drives on radiators; and
- installation of photo sensors on all outside lighting.

Station service reductions have also come through the education and resulting heightened awareness of plant personnel. Small measures are highlighted, such as turning off lights when plants are unattended, turning heaters down or off when not required, and ensuring that any pipes or other

equipment that require heat tracing during winter months are shut-off during spring and summer months.


Since 1990/91 NTPC has successfully reduced overall Corporate station service. Through frequent audits of operations and diligent efforts to implement station service reducing technologies and practices we will continue to reduce our station service in future years. Figure 8 illustrates station service for NTPC diesel generating facilities (except standby plants) for 1990/91 and 2010/11. Note: there is no generation for Colville Lake in 1990/91 as the plant was commissioned in 1992.

Colville Lake Residual Heat Project

In recent years, the Corporation has been a leader in a number of projects to recover and distribute waste heat from our diesel engines to both external customers and our own facilities.

Prior to 2001/02, the Colville Lake facility was heated electrically. Station service for this facility ranged from 20% to 37% of annual gross generation, well in excess of NTPC's acceptable level of 5%. In 2001/02, a retrofit of the modular plant was completed which provided residual heat for the

Figure 8: Station Service for Diesel Plants (excluding standby plants) for 1990/91 and 2010/11



By diligently monitoring facility statistics, NTPC is able to identify sites where station service requirements are in excess of acceptable levels. NTPC set a target for each facility to achieve and maintain a station service less than or equal to 5% of its total generation. NTPC will continue to monitor station service and work to reduce it at the four plants still exceeding the 5% target while maintaining all other site station service percentages below the target.

plant, office/warehouse, and crew trailer. This resulted in a total station service decrease of 47,746 kWh between 2000/01 and 2010/11. This translates into a decrease of nearly 50 tonnes of CO₂ equivalent GHG emissions resulting primarily from the utilization of residual heat.

Fort Smith Electric Heat Project

In 2008, Breynat Hall and JBT Elementary School in Fort Smith were converted from diesel heating systems to electric heat. These electric heating systems are powered by excess generation from the Taltson Hydro facility. In 2009 a third building, the Department of Transportation parking and maintenance garage, was also converted to electric heat. To date, conversion of the three buildings to electric heat has resulted in a cumulative savings of 525,487 L of diesel fuel oil, displacing 1,414 tonnes of CO₂e.

Jackfish Electric Boiler Installation

Electric boilers have been installed to heat the Yellowknife power plants, which are now used as backup to hydro generation, rather than using diesel fuel to heat the plants. This electricity is excess hydropower and displaces approximately 84,000 L of diesel per year. When the engines are running they are used to heat the facility.

Alternative Generation Fuels / Methods

In recent years NTPC has undertaken a number of initiatives to reduce GHG emissions by utilizing alternative methods or fuel sources to generate power. Some of these initiatives have involved major capital projects such as the Inuvik Gas Project and major changes to hydro infrastructures. Some alternative generation methods are summarized below.

Bluefish Hydro Purchase

NTPC purchased the Bluefish hydro facility in the spring of 2003. The Bluefish hydro facility was used primarily to serve Con Mine energy requirements. In November of 2003 Con Mine terminated mining operations and NTPC was able to displace diesel generation with Bluefish hydro generation to supply Yellowknife's electricity demands. Between 2011/12 and 2014/15 Bluefish hydropower will displace approximately 143,432 tonnes of CO₂e emissions.



Proposed Hydro Developments

NTPC continues to investigate the feasibility of additional hydro developments. The proposed Great Bear Hydro project has been researched since 2001 and is still in the pre-feasibility/conceptual stage. Although not included in the initial pipeline design, it is envisioned in the long term that energy from the Great Bear River would be used to supply power to the proposed Mackenzie Valley natural gas pipeline. The next major step in this project is to conduct feasibility and environmental studies.

NTPC's second proposed new hydro initiative is the Taltson Hydro Expansion Project. This would involve the expansion of the existing Taltson hydro site to power the proposed Gahcho Kue mine site and the three operating diamond mines (Ekati, Diavik, and Snap Lake). This is currently in the environmental assessment stage.

NTPC has worked closely with local aboriginal partners regarding power generation for each of the proposed projects. Life-cycle analyses of the pipeline and mines were carried out to determine both GHG and dollar savings when replacing natural gas and diesel generated electricity with hydroelectricity.

Mini Hydro in Lutsel K'e


NTPC is conducting a feasibility study on the Lutsel K'e Mini-Hydro project. The project involves building a 500–1000 kW mini-hydro plant on the Snowdrift River to serve the Lutsel K'e electricity and heating requirements. Upcoming work includes determining the business case with the community of Lutsel K'e and a detailed economic analysis of the project. If the project goes ahead it will reduce the community's annual diesel fuel consumption by about 800 kL, approximately 400 kL of which is currently used to generate electricity.

these communities, HPS lights will be exchanged following the end-of-life of the existing MV lights.

NTPC is also conducting a trial of Light Emitting Diode (LED) streetlights, which use less than half the power of HPS lights, with six installed to date. Figure 10 illustrates the average amount of energy required per streetlight in NTPC serviced communities. As more MV lights are replaced with HPS lights, the average kWh required per streetlight will decrease.

GHG savings from our continuing streetlight replacement program are shown in Table 7.

Figure 9: kWh per Streetlight per Year



Streetlight Replacement

NTPC began converting community streetlights from Mercury Vapour (MV) to the more efficient High-Pressure Sodium (HPS) during the 1995/96 fiscal year. To date, twenty-one communities have had every streetlight converted to HPS. Four communities are still in the conversion process. NTPC accessed funding available from the GNWT Department of Environment and Natural Resources (ENR) to aid in the replacement of all MV streetlights in these communities with HPS lights. For



Transmission and Distribution Lines

Line losses increase generation requirements, which increase greenhouse gas emissions. As required, transmission and distribution systems will be upgraded with new efficient conductors and transformers in order to reduce line losses.

Residential/Commercial Energy Efficiency Program

Customer Research Surveys completed in 2000 and 2002 confirmed that customers would like more information on how to make their homes more energy efficient. To meet their needs, NTPC implemented a Residential Energy Efficiency Program in 2002/03 targeting the 13 remote northern communities of the Delta-Sahtu region. This program proved highly successful with nearly 500 customers participating in the program. Each participant received valuable energy efficiency tips as well as energy saving light bulbs and an energy-efficient showerhead. The energy efficiency assessments showed that high power consumption was primarily caused by inefficient, outdated, or poorly maintained electrical appliances. Due to the success of this program in the Delta-Sahtu region, NTPC ran the program in the other regions in 2004/05 and 2005/06, and in 2006/07 to several of our largest commercial customers. The program includes the following key objectives:

- To conduct comprehensive energy efficiency audits of residential homes;
- To provide customers with information per-

taining to energy efficiency solutions and how to obtain them;

- To provide customers with information pertaining to climate change and how energy conservation can make a difference; and
- To discuss with customers any concerns regarding the service and electricity currently supplied to them by NTPC.

Now that all of our residential customers have been offered the program and due to its success, NTPC is hoping to offer the program again on a rotating basis, and to continue offering the program to large commercial customers.

Results in Comparison to Targets

GHG Emissions

Our internal target to reduce GHG emissions by 10% of 1996/97 levels in 10 years was achieved by 1998/99. To date, we have reduced our cumulative CO₂ equivalent emissions by 811,792 tonnes and achieved a 51% decrease in 2010/11 from 1990/91 levels.

CO₂e Station Service Target

To date NTPC has successfully reduced station service at all but six facilities to less than 5% of their total generations. NTPC will continue to monitor station service and, where feasible, implement training and technologies to reduce station service at the remaining six diesel-generating facilities to meet the 5% target.



CLIMATE CHANGE AWARENESS


NTPC is committed to both employee and customer education regarding energy awareness. We hope to create an awareness of energy efficient practices and measures that can be implemented by all to ensure that the maximum benefit is derived from the electricity produced. Climate change issues are discussed in conjunction with many of our programs to promote energy awareness and conservation. The communication avenues discussed below are utilized to inform employees and the public of the many ways in which they can contribute to reductions in GHG production.

Brief energy saving tips are printed on power bills and slips of paper containing additional tips are included in the envelopes with each monthly power bill.

The simple addition of a bicycle rack outside of our head office has provided an incentive for emissions reduction by employees, both inside and outside of work. As well, a number of employees across the Corporation make a point of walking to and from work. This is not only healthy for the individual and an environmentally friendly alternative to driving, but sets a good example for other members of their respective communities.

NTPC was awarded **Gold Champion Level Reporter** status by the Registry for our 2009/10 GHG report submission. This, along with all previous GHG reports, are made available on both our internal and external websites and our reporting status and awards are promoted to our customers through our website, on letterhead, and in local newspapers.

NTPC was a founding member of the **Arctic Energy Alliance (AEA)** and is a sustaining member today. The AEA is a not-for-profit organization established in 1997. The AEA's mandate is to help reduce the financial costs and environmental impacts associated with energy and utility ser-



CONCLUSION

The Northwest Territories Power Corporation has undertaken many successful initiatives towards reducing greenhouse gases. Our GHG reports demonstrate our commitment to combating climate change, as we believe that environmental issues should be at the forefront of all business. NTPC is committed to further reducing GHG emissions wherever feasible. We will continue to implement new ideas and strategies to conserve fuel usage and subsequent emissions while openly reporting our progress and initiatives.



For more information please contact:

Northwest Territories Power Corporation
4 Capital Drive
Hay River, NT X0E 1G2

Telephone: 867 - 874 - 5200

Fax: 867 - 874 - 5251

Email: info@ntpc.com

Or visit our website at www.ntpc.com



Appendix A: NTPC Greenhouse Gas Emissions Savings 1990/91 to 2014/15

	1990/91	1995/96	1996/97	1997/98	1998/99	1999/00	2000/01	2001/02	2002/03	2003/04	2004/05	2005/06	2006/07	2007/08	2008/09	2009/10	2010/11	2011/12	2012/13	2013/14	2014/15
Alternative Generation/ Fuels																					
Snare Cascades																					
CO ₂			17,593	16,916	17,374	21,541	19,984	17,732	19,126	18,783	18,783	20,990	12,110	17,771	16,769	14,253	15,221	20,443	20,514	20,623	20,731
CH ₄			0.88	0.84	0.87	1.08	1.00	0.89	0.96	0.94	0.94	1.05	0.60	0.89	0.84	0.71	0.76	1.02	1.02	1.03	1.04
N ₂ O			2.64	2.54	2.61	3.24	3.00	2.66	2.87	2.82	2.82	3.15	1.82	2.67	2.52	2.14	2.29	3.07	3.08	3.10	3.11
CO ₂ Equiv.			18,431	17,721	18,201	22,566	20,935	18,576	20,037	19,677	19,677	21,989	12,687	18,617	17,568	14,932	15,945	21,416	21,491	21,605	21,718
Snare Rapids G2¹																					
CO ₂			2,329	1,906	1,906	1,466	2,488	2,351	846	186	113	113	1,027	790	1,304	2,014	-	-	-	-	-
CH ₄			0.12	0.10	0.10	0.07	0.12	0.12	0.04	0.01	0.01	0.01	0.05	0.04	0.07	0.10	-	-	-	-	-
N ₂ O			0.35	0.29	0.29	0.22	0.37	0.35	0.13	0.03	0.02	0.02	0.15	0.12	0.20	0.30	-	-	-	-	-
CO ₂ Equiv.			2,440	1,997	1,997	1,535	2,607	2,462	886	195	118	118	1,076	828	1,366	2,110	-	-	-	-	-
Norman Wells Purchased Power																					
CO ₂	921	875	829	925	931	871	859	859	877	1,010	965	930	1,012	1,024	992	1,090	948	987	986	986	984
CH ₄	-0.75	-0.72	-0.68	-0.76	-0.76	-0.71	-0.70	-0.70	-0.72	-0.83	-0.79	-0.76	-0.83	-0.84	-0.81	-0.79	-0.78	-0.81	-0.81	-0.81	-0.80
N ₂ O	0.83	0.79	0.75	0.84	0.84	0.79	0.78	0.78	0.79	0.91	0.87	0.84	0.92	0.93	0.90	0.90	0.86	0.89	0.89	0.89	0.89
CO ₂ Equiv.	1,163	1,106	1,048	1,169	1,176	1,101	1,086	1,085	1,108	1,276	1,219	1,175	1,278	1,294	1,253	1,352	1,198	1,246	1,246	1,245	1,243
Inuvik Gas Project																					
CO ₂						-275	51	-104	-909	-1,127	-1,129	-1,012	-1,981	-2,047	-1,712	-1,802	-1,212	-1,740	-1,749	-1,758	-1,751
CH ₄						-1.28	-2.16	-2.47	-2.48	-2.58	-2.60	-2.52	-3.11	-3.20	-3.16	-3.19	-2.53	-3.05	-3.07	-3.09	-3.07
N ₂ O						1.06	1.89	2.13	1.98	2.03	2.04	2.00	2.32	2.38	2.42	2.42	1.96	2.32	2.33	2.34	2.33
CO ₂ Equiv.						27	592	505	-346	-553	-550	-446	-1,328	-1,375	-1,028	-1,117	-656	-1,085	-1,090	-1,096	-1,092
Bluefish Purchased Power																					
CO ₂		23,929	33,388	31,814	26,731	34,464	37,489	38,720	35,938	34,758	24,361	31,030	27,834	15,810	27,319	38,145	24,482	34,228	34,228	34,228	34,228
CH ₄		1.20	1.67	1.59	1.34	1.72	1.87	1.93	1.79	1.74	1.22	1.55	1.39	0.79	1.36	1.91	1.22	1.71	1.71	1.71	1.71
N ₂ O		3.59	5.02	4.78	4.02	5.18	5.63	5.82	5.40	5.22	3.66	4.66	4.18	2.37	4.10	5.73	3.68	5.14	5.14	5.14	5.14
CO ₂ Equiv.		25,068	34,978	33,329	28,003	36,105	39,274	40,563	37,649	36,413	25,521	32,507	29,159	16,563	28,620	39,961	25,648	35,858	35,858	35,858	35,858

¹ Snare Rapids G2 unit does not operate during average to low water years. As forecasting for the hydro system assumes average water levels, zero G2 generation is also forecast. However, on average, the G2 unit has accounted for approximately 0.02% of the total Snare hydro generation since installation, so some generation is anticipated even if not forecast.

Note: 1991/92, 1992/93, 1993/94 and 1994/95 data has been removed from the table to allow room for table expansion. Please see previous years' reports for this data.



Appendix A: NTPC Greenhouse Gas Emissions Savings 1990/91 to 2014/15

	1990/91	1995/96	1996/97	1997/98	1998/99	1999/00	2000/01	2001/02	2002/03	2003/04	2004/05	2005/06	2006/07	2007/08	2008/09	2009/10	2010/11	2011/12	2012/13	2013/14	2014/15
Station Service Reduction/Residual Heat Projects																					
Station Service/Residual Heat Savings																					
CO ₂		375	311	290	341	189	157	168	169	151	194	166	186	220	158	109	140	140	140	140	140
CH ₄		0.02	0.02	0.01	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
N ₂ O		0.06	0.05	0.04	0.05	0.03	0.02	0.03	0.03	0.02	0.03	0.02	0.03	0.03	0.02	0.02	0.02	0.02	0.02	0.02	0.02
CO ₂ Equiv.		393	326	303	357	198	164	176	177	159	203	173	195	231	166	114	146	146	146	146	146
Fort McPherson Residual Heat																					
CO ₂				498	413	462	439	467	429	152	0	0	418	457	457	603	453	365	362	354	347
CH ₄				0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.00	0.00	0.02	0.02	0.02	0.03	0.02	0.02	0.02	0.02	0.02
N ₂ O				0.07	0.06	0.07	0.07	0.07	0.06	0.02	0.00	0.00	0.06	0.07	0.07	0.09	0.07	0.05	0.05	0.05	0.05
CO ₂ Equiv.				522	432	484	460	489	449	159	0	0	437	478	478	631	475	383	379	371	364
New Engine Upgrades/PLCs																					
Improved Fuel Efficiency Savings																					
CO ₂		3,783	4,067	4,006	5,003	3,570	3,484	3,877	4,243	4,068	4,038	3,898	4,044	4,047	4,075	4,186	4,406	4,182	4,188	4,193	4,167
CH ₄		0.19	0.20	0.20	0.25	0.18	0.17	0.19	0.21	0.20	0.20	0.19	0.20	0.20	0.20	0.21	0.22	0.21	0.21	0.21	0.21
N ₂ O		0.57	0.61	0.60	0.75	0.54	0.52	0.58	0.64	0.61	0.61	0.59	0.61	0.61	0.61	0.63	0.66	0.63	0.63	0.63	0.63
CO ₂ Equiv.		3,964	4,260	4,197	5,241	3,740	3,650	4,062	4,445	4,262	4,231	4,083	4,237	4,240	4,269	4,385	4,616	4,381	4,387	4,393	4,365
Streetlight Upgrades																					
Streetlight Savings																					
CO ₂			24	82	94	131	155	150	172	226	274	354	390	425	363	431	435	435	435	435	435
CH ₄			0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.02	0.03	0.02	0.03	0.03	0.03	0.03	0.03	0.03
N ₂ O			0.00	0.01	0.01	0.02	0.02	0.02	0.02	0.03	0.04	0.05	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.06
CO ₂ Equiv.			25	85	98	137	162	157	180	237	286	370	408	444	380	450	454	454	454	454	454
Annual Totals																					
CO ₂	921	28,962	58,542	56,437	52,791	62,418	65,106	64,219	60,890	58,208	47,599	56,468	45,040	38,497	49,725	59,027	47,055	59,040	59,106	59,202	59,282
CH ₄	-0.75	0.69	2.20	2.02	1.83	1.09	0.34	-0.01	-0.16	-0.49	-1.00	-0.46	-1.64	-2.05	-1.46	-0.99	-0.93	-0.87	-0.88	-0.89	-0.87
N ₂ O	0.83	5.01	9.42	9.18	8.63	11.13	12.31	12.44	11.93	11.70	10.09	11.33	10.14	9.24	10.89	12.29	9.93	12.19	12.21	12.24	12.24
CO ₂ Equiv.	1,163	30,530	61,483	59,238	55,407	65,756	68,768	67,919	64,404	61,587	50,419	59,601	47,742	40,875	52,692	62,367	49,659	62,347	62,419	62,524	62,605
Cumulative Totals Since 1990/91																					
CO ₂	921	95,059	153,601	210,038	262,829	325,247	390,353	454,572	515,462	573,670	620,348	674,111	698,838	714,818	744,901	774,967	917,081	976,121	1,035,227	1,094,429	1,153,711
CH ₄	-0.75	-0.14	2.06	4.08	5.91	7.00	7.34	7.33	7.18	6.68	6.43	6.65	4.81	2.49	0.91	-0.77	-1.85	-2.72	-3.60	-4.49	-5.36
N ₂ O	0.83	18.53	27.95	37.13	45.76	56.89	69.20	81.65	93.57	105.27	114.53	124.75	131.13	136.25	143.45	150.73	179.19	191.38	203.59	215.83	228.07
CO ₂ Equiv.	1,163	100,801	162,284	221,522	276,929	342,685	411,453	479,371	543,776	605,363	655,782	715,383	761,962	799,803	831,011	869,575	968,717	1,031,064	1,093,483	1,156,007	1,218,611



The Northwest Territories Power Corporation would like to thank the following people for their contributions to the 2010/11 Greenhouse Gas Report:

**Arlene Alcos
Joshua Clark
Emanuel DaRosa
David Dewar
Ken Dies
Drew Farmer
April Glaicar
Judy Goucher
Paul Grant
Jean Ramsay
Edward Smith**

