

NTPC Health & Safety Alert

Incident Summary – November 2016



Background

The following incidents took place in November 2016. Medium and High Reasonable Potential for Harm (RPH) incidents are covered in more detail in separate alerts.

Practical Guidance

11-03-16, Fort Smith, NTPC Incident, High RPH:

- Event: Digger Truck slid into ditch and rolled onto side. No Injuries.
- Response: Incident Investigation

11-04-16, Ulukhaktok, NTPC Incident, Low RPH:

- Event: Fuel Spilled while filling tank
- Response: Checksheet to be developed

11-07-16, Inuvik, NTPC Incident, Med RPH:

- Event: Meter change produced flash and damage to meter
- Response: Review Safe Job Procedure with staff. Investigation.

11-09-16, Yellowknife, NTPC Incident, Low RPH:

- Event: Falling pole piece damaged shroud on Digger boom
- Response: Tagged out until repairs made

11-10-16, Fort Simpson, NTPC Incident, Low RPH:

- Event: Fuel spill in tank berm
- Response: Cleaned up and reported. Inspect alarm.

11-15-16, Inuvik, NTPC Incident, Med RPH:

- Event: Switching error while isolating breaker

<ul style="list-style-type: none"> - Response: Incident Investigation
<p>11-15-16, Snare, NTPC Incident, Med RPH:</p> <ul style="list-style-type: none"> - Event: Hazardous chemical shipped on passenger plane - Response: Incident Investigation
<p>11-18-16, Fort Simpson, NTPC Incident, Low RPH:</p> <ul style="list-style-type: none"> - Event: Slip and fall outside CIBC bank - Response: Inform business about the icy path
<p>11-19-16, Tulita, Public Incident, Low RPH:</p> <ul style="list-style-type: none"> - Event: Discovered power pole had been cut with chainsaw - Response: RCMP report. Pole to be replaced by T&D
<p>11-23-16, Yellowknife, NTPC Incident, Low RPH:</p> <ul style="list-style-type: none"> - Event: Broken pallet skid contributed to load falling off of forklift forks - Response: Inform shipper of poor condition of pallets
<p>11-27-16, Inuvik, Public Incident, Med RPH:</p> <ul style="list-style-type: none"> - Event: Public vehicle hit guy wire pole. No power line down - Response: RCMP report
<p>11-27-16, Tuktoyaktuk, NTPC Incident, Low RPH:</p> <ul style="list-style-type: none"> - Event: glycol spill in plant - Response: Cleaned up and reported. Maintenance staff to make repairs
<p>11-27-16, Yellowknife, NTPC Incident, Med RPH:</p> <ul style="list-style-type: none"> - Event: UPS damaged while being moved - Response: Incident Investigation