

NTPC Health & Safety Alert

Incident Summary – October 2016



Background

The following incidents took place in October 2016. Medium and High Reasonable Potential for Harm (RPH) incidents are covered in more detail in separate alerts.

Practical Guidance

07-21-16, Fort McPherson, NTPC Incident, Low RPH:

- Event: Fuse blown after glycol spill
- Response: Fuse replaced and other fuses checked.

09-12-16, Inuvik, Public Incident, Med RPH:

- Event: Dump truck snagged neutral line
- Response: Police report. Requested incident report. Safety briefing with the public contractor

09-20-16, Ulukhaktok, NTPC Incident, Low RPH:

- Event: Discovered damage to front bumper of truck
- Response: Training on performing vehicle checks

09-26-16, Fort Good Hope, Public Incident, Low RPH:

- Event: NTPC truck windshield damaged by member of the public
- Response: Police report. Windshield to be replaced

09-30-16, Fort McPherson, Contractor Incident, Low RPH:

- Event: Repetitive strain injury
- Response: Review of SWP

10-05-16, Nahanni Butte, NTPC Incident, Low RPH:

- Event: Cell phone lost while walking
- Response: New phone and new holster ordered

10-10-16, Inuvik, NTPC Incident, Low RPH:

- Event: Repetitive strain injury to arm/wrist
- Response: Modified work duties

10-11-16, Nahanni Butte, NTPC Incident, Low RPH:

- Event: Low oil in engine caused power outage
- Response: Inspection of engine

10-12-16, Bluefish, NTPC Incident, Low RPH:

- Event: Boat engine trouble
- Response: Boat sent for repairs

10-12-16, Norman Wells, NTPC Incident, Low RPH:

- Event: Ankle strain while walking
- Response: No first aid, no medical aid

10-15-16, Fort Simpson, NTPC Incident, Med RPH:

- Event: Coffee pot left on hot burner
- Response: Install sign. Investigate auto-shutoff model coffee maker

10-17-16, Inuvik, Public Incident, High RPH:

- Event: Power line torn down
- Response: Police report. Requested incident report. Safety briefing with the public contractor

10-19-16, Fort Good Hope, Public Incident, Med RPH:

- Event: Stolen truck collided with power pole
- Response: Police report. Line crew sent in to do repairs